Sample Number	School	Floor #	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action - Required for any outlet > 5.0 parts per billion	Resampling Dates Required after Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 part per billion)	Is Outlet in Compliance?	Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2021-SO-PS-001	Palisades School	1	Children's Bathroom Sink Faucet(in Hallway next to Main Office)	5/26/21	4.5	Not Required	Not Required	4.5	Yes	6/15/21	Not Applicable
2021-SO-PS-002	Palisades School	1	Staff Bathroom Sink Faucet (in Hallway next to Main Office)	5/26/21	5.6	Exempt from further Testing - bathrooms not required to be sampled under new regulations	Not Required	Not applicable	No	1/1/2023	Not Applicable
2021-SO-PS-003	Palisades School	1	Hallway next to Classroom 1 -Bathroom Sink Faucet	5/26/21	3.1	Not Required	Not Required	3.1	Yes	6/15/21	Not Applicable
2021-SO-PS-004	Palisades School	1	Classroom Room 3 - Single Sink Faucet	5/26/21	5.8	Do Not Drink Sign Installed; Aerator to be changed then resampled	TBD	5.8	No	6/15/21	Not Applicable
2021-SO-PS-005	Palisades School	1	Hallway Next to Room 3- Bathroom Single Sink Faucet	5/26/21	5.3	Exempt from further Testing - bathrooms not required to be sampled under new regulations	Not Required	Not applicable	Yes	1/1/23	Not Applicable
2021-SO-PS-006	Palisades School	1	Classroom Room 5 - Sink (left when facing) Faucet 1	5/26/21	<1.0	Not Required	Not Required	<1.0	Yes	6/15/21	Not Applicable
2021-SO-PS-007	Palisades School	1	Classroom Room 5 - Sink (right when facing) Faucet 2	5/26/21	1.2	Not Required	Not Required	1.2	Yes	6/15/21	Not Applicable
2021-SO-PS-008	Palisades School	1	Classroom Room 5 - Bathroom Sink Single Faucet	5/26/21	1.6	Not Required	Not Required	1.6	Yes	6/15/21	Not Applicable
2021-SO-PS-009	Palisades School	1	Classroom Room 6 - Sink (left when facing) Faucet 1	5/26/21	9.8	Do Not Drink Sign Installed; Aerator changed; to be resampled	TBD	9.8	No	6/15/21	Not Applicable
2021-SO-PS-010	Palisades School	1	Classroom Room 6 - Sink (right when facing) Faucet 2	5/26/21	2.3	Not Required	Not Required	2.3	Yes	6/15/21	Not Applicable
2021-SO-PS-011	Palisades School	1	Classroom Room 6 - Bathroom Sink Single Faucet	5/26/21	1.6	Not Required	Not Required	1.6	Yes	6/15/21	Not Applicable
2021-SO-PS-012	Palisades School	1	Classroom Room 8 - Sink (left when facing) Faucet 1	5/26/21	2.0	Not Required	Not Required	2	Yes	6/15/21	Not Applicable
2021-SO-PS-013	Palisades School	1	Classroom Room 8 - Sink (left when facing) Faucet 2	5/26/21	1.4	Not Required	Not Required	1.4	Yes	6/15/21	Not Applicable
2021-SO-PS-014	Palisades School	1	Classroom Room 9 - Sink (left when facing) Faucet 1	5/26/21	1.9	Not Required	Not Required	1.9	Yes	6/15/21	Not Applicable
2021-SO-PS-015	Palisades School	1	Classroom Room 9 - Sink (right when facing) Faucet 2	5/26/21	2.1	Not Required	Not Required	2.1	Yes	6/15/21	Not Applicable
2021-SO-PS-016	Palisades School	1	South Kitchen (Room 10) Single Sink Faucet	5/26/21	7.7	Do Not Drink Sign Installed; Aerator changed; to be resampled	TBD	Pending	No	Pending	Not Applicable
2021-SO-PS-017	Palisades School	1	North Kitchen (Room 11/stove) - Small White Sink Faucet	5/26/21	33.1	Outlet exempted per Program Director	Not Required	Not Required	Not Applicable	Not Applicable	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2021-SO-PS-018	Palisades School	1	North Kitchen (Room 11/stove) - Large Metal Sink Faucet	5/26/21	12.2	Do Not Drink Sign Installed; Aerator changed; to be resampled	TBD	12.2	No	6/15/21	Not Applicable
2021-SO-PS-019	Palisades School	Exterior	Outside of Kitchen (by dumpster)- Exterior Hose Bib	5/26/21	3.8	Not Required	Not Required	3.8	Yes	6/15/21	Not Applicable
2021-SO-PS-020	Palisades School	1	Custodial Room (Hallway by Room 3) Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students; room is kept locked.
Spreadsheet updates 7/27/23											